



D & K Intertrade Pte Ltd

10 Jalan Besar, #11-03 Sim Lim Tower, Singapore 208787

Tel : 65 - 62941788

Fax : 65 - 62941275

Website: www.dnk.com.sg

Email: sales@dnk.com.sg

YURI Electrical Power Cable


LV Aerial Bundle Cable

Al/XLPE - 0.6/1(1.2) kV

Applied Standard : IEC 60502-1

Construction

1. Conductor : Standard plain aluminum wires, Circular round compacted
2. Insulation : Black XLPE (2% Carbon Content)



Core Identification

Longitudial raised ribs on insulation surface

Phase core : 1,2 & 3 rib for 1st,2nd ,3rd

Neutral core ; No rib

YURI ABC-LV-4C35 0.6/1(1.2)kV 4C*35mm² AL/XLPE IEC-60502-1

No.	Items	Unit	Nominal cross-section (mm ²)
			4 x 35
1	Rate Voltage	kV	0.6/1(1.2)
2	Construction of conductor	n/mm	Round Compacted
3	Diameter of Conductor	mm	7.0
4	Thickness of Insulation	mm	1.3
5	Approx Overall diameter of cable	mm	23.0
6	Weight of cable (approx)	kg/km	512.0
7	Minimum breaking load	kN	28.0
8	DC resistance of conductor at 20°	Ohm/km	0.868
9	Insulation resistance	Mohm.km	1500
10	Test Voltage for 5 minute	kV	3.5
11	Packaging length per drum	m	1000

Website: www.dnk.com.sg | Email: sales@dnk.com.sg



D & K Intertrade Pte Ltd

10 Jalan Besar, #11-03 Sim Lim Tower, Singapore 208787

Tel : 65 - 62941788

Fax : 65 - 62941275

Website: www.dnk.com.sg

Email: sales@dnk.com.sg

YURI Electrical Power Cable


LV Aerial Bundle Cable

Al/XLPE - 0.6/1(1.2) kV

Applied Standard : IEC 60502-1

Construction

1. Conductor : Standard plain aluminum wires, Circular round compacted
2. Insulation : Black XLPE (2% Carbon Content)



Core Identification

Longitudinal raised ribs on insulation surface

Phase core : 1,2 & 3 rib for 1st,2nd ,3rd

Neutral core ; No rib

YURI ABC-LV-4C95 0.6/1(1.2)kV 4C*95mm² AL/XLPE IEC-60502-1

No.	Items	Unit	Nominal cross-section (mm ²)
			4 x 95
1	Rate Voltage	kV	0.6/1(1.2)
2	Construction of conductor	n/mm	Round Compacted
3	Diameter of Conductor	mm	11.6
4	Thickness of Insulation	mm	1.7
5	Approx Overall diameter of cable	mm	36.0
6	Weight of cable (approx)	kg/km	1297.0
7	Minimum breaking load	kN	53.2
8	DC resistance of conductor at 20°	Ohm/km	0.32
9	Insulation resistance	Mohm.km	1500
10	Test Voltage for 5 minute	kV	3.5
11	Packaging length per drum	m	1000

Website: www.dnk.com.sg | Email: sales@dnk.com.sg